# Energy Efficiency in MENA Workshop 28 September 2016




Intelligent Efficiency at Work: Data Driven HVAC system Optimization

How Systems Level Integration and **Intelligence** can reduce energy consumption and operating costs

Firas Obeido, Chief Technology Officer, Smart Automation Energy

# Energy Efficiency project savings (July 1<sup>st</sup> – July 31<sup>st</sup> 2016)





**BASELINE ENERGY** for July 2016 (kWh)

752,217

ACTUAL ENERGY for July 2016 (kWh)

649,440

FINAL ENERGY SAVINGS %

14%

ADJUSTED ENERGY for July 2016 (kWh)

2,653

FINAL ENERGY COST SAVINGS (AED)

46,916


FINAL SAVINGS for July 2016 (kWh)

105,430

## **Cumulative Monthly Energy Savings**




Projected energy savings of AED 352,000 by June 30<sup>th</sup> 2017



## **Cumulative Monthly Energy Cost Savings**




Projected energy savings of AED 352,000 by June 30<sup>th</sup> 2017



# Daily energy consumption – Baseline vs. Actual (kWh)





Energy savings during the first 13 days of July were higher than the energy savings during the last 17 days of July

This is due to the unplanned FAHU-2 exhaust fan shutdown during the last 17 days of the month

Reduced electrical energy consumption due to exhaust fan OFF for the duration of 18 days is 10399.3 kWh.

As for the increase in cooling energy consumed due to NO heat recovery is 13052.7 kWh.

With a reduction in electricity consumption and an increase in cooling consumption, the overall addition to the monthly energy savings is equal to 13052.7kWh – 10399.3 kWh = 2653 kWh.

# Energy Efficiency project savings (Aug. 1<sup>st</sup> – Aug. 31<sup>st</sup> 2016)



Cumulative Baseline Energy YTD 2016 (kWh)

Adjusted Energy YTD 2016 (kWh)

Final savings
Energy YTD 2016
(kWh)

1,422,109

1,266,384

**Actual Energy YTD** 

2016 (kWh)

20,883

193,905

FINAL ENERGY SAVINGS YTD %

13.4%


FINAL ENERGY COST SAVINGS YTD (AED)

86,288

### **Cumulative Monthly Energy Cost Savings**




Projected energy savings of AED 352,000 by June 30<sup>th</sup> 2017



# Daily energy consumption – Baseline vs. Actual (kWh)





Energy savings during the first 13 days of July were higher than the energy savings during the last 17 days of July

This is due to the unplanned FAHU-2 exhaust fan shutdown during the last 17 days of the month


Reduced electrical energy consumption due to exhaust fan OFF for the duration of 18 days is 10399.3 kWh.

As for the increase in cooling energy consumed due to NO heat recovery is 13052.7 kWh.

With a reduction in electricity consumption and an increase in cooling consumption, the overall addition to the monthly energy savings is equal to 13052.7kWh – 10399.3 kWh = 2653 kWh.

#### Reduction of chilled water temperature





Non routine Adjustment of energy savings based on static factor – reduction of chilled water temperature setpoint

Between 15<sup>th</sup> July & 21<sup>st</sup> August 2016, rescheduling in chiller operation resulted in lower chilled water temperature from 7 deg C to 6 deg C. The temperature setpoint was restored to 7 deg C on 22<sup>nd</sup> of August.

Increased energy consumption from 15<sup>th</sup> July to 21<sup>st</sup> August 2016 of 18,180 KWh (8,090.2 AED).

# Energy Efficiency project savings (July 1<sup>st</sup> – Sep. 20<sup>th</sup> 2016)



Cumulative Baseline Energy YTD 2016 (kWh)

2016 (kWh)

Adjusted Energy YTD 2016 (kWh)

Final savings
Energy YTD 2016
(kWh)

1,903,562

1,627,680

**Actual Energy YTD** 

20,883

296,764

FINAL ENERGY SAVINGS YTD %


16.0%

FINAL ENERGY COST SAVINGS YTD (AED)

132,060


### Adjusted baseline vs. Actual energy consumption






## CO2 levels vs. FAHU fan speed







- CO2 levels are much lower than ASHRAE standards (900 ppm -1100ppm).
- FAHUs supply fan speed no less than 50%.
- FAHUs extract fan speed no less than 70%

#### Challenges & Recommendations



#### Challenges

- Each chiller has different set point.
- Temperatures across chillers and headers are not reliable.
- Number of chillers operating during the day and night remain the same even if cooling load is different.
- No chiller optimization.

#### Recommendations

- Continuously monitor temperatures for each chiller
- Upgrade BMS system
- Install of CPM

#### **Impact**

- Full visibility of HVAC system.
- Continuous commissioning
- Collection and analysis of operational data to further optimize energy consumption.



# Questions?

## **Smart Automation Energy LLC**

Firas Obeido (CEM, CMVP, CLP)

Chief Technology Officer
Barsha Business Square, Office 502, Barsha,
PO BOX 393427, Dubai, UAE
T +971 4 3794984 F +971 4 3794986 M +971 56 182 9409
E firas.obeido@smartae.ae W www.smartae.ae